



STATE OF WASHINGTON
DEPARTMENT OF ECOLOGY
P.O. Box 47775 • Olympia, Washington 98504-7775 • (360) 407-6300

May 6, 2003

CERTIFIED MAIL

Greg Hudson
Domsea Broodstock
10420A 173RD Ave. SW
Rochester, WA 98579-8515

Dear Mr. Hudson:

Re: Modification of National Pollutant Discharge Elimination System (NPDES) Permit No.
WA0040819

The NPDES waste discharge permit issued for your facility on January 19, 2000, is hereby modified as of this date in the following particulars:

- Addition of Chlorine Residual limits for Outfall 002.
- Addition of Schedule of Compliance for the installation of a dechlorination device.

The enclosed revised page(s) of the permit are your official copy of the modification.

This permit modification may be appealed. Appeal rights extend only to the explicit modification and not the entire permit. Your appeal must be filed with the Pollution Control Hearings Board, P.O. Box 40903, Olympia, Washington 98504-0903 within 30 days of the receipt of this permit. At the same time, your appeal must also be sent to the Department of Ecology, Fiscal Office, P.O. Box 47615, Olympia, Washington 98504-7615, and to Ecology's Southwest Regional Office, P.O. Box 47775, Olympia, Washington 98504-7775. Your appeal alone will not stay the effectiveness of this permit. Stay requests must be submitted in accordance with Revised Code of Washington (RCW) 43.21B.320. These procedures are consistent with Chapter 43.21B RCW.

Any appeal must contain the following in accordance with the rules of the hearing board:

- a. The appellant's name and address;
- b. The coverage date and number of the permit appealed;
- c. A description of the substance within the permit that is the subject of the appeal;

Greg Hudson

Page 2

- d. A clear, separate, and concise statement of every error alleged to have been committed;
- e. A clear and concise statement of facts which the requester relies to sustain his or her statements of error; and
- f. A statement setting forth the relief sought.

Sincerely,

Original signed by:

Kelly Susewind, P.E., P.G.
Southwest Region Manager
Water Quality Program

KS:ljc

Enclosures